

Phoenix Contact Inc.  
P.O. BOX 4100  
Harrisburg, PA 17111-0100  
Phone: 717-944-1300  
Fax: 717-944-1625

## Product Change Notification

### PCN-TT-737-2017

Business Unit	Product Line Code	Type of Change	Action	Date of Issue
TT - Trabtech	CL1	Product Change Notification	Notify Distributors and Field	7/10/2017

The following Phoenix Contact products have been modified. Existing specifications will be met or exceeded. Please review and acknowledge this document and inform your personnel as needed.

#### Description for Product Change Notification

To comply with the updated requirements from the European Union, the printing on the SEC series surge protection products has been changed to include additional voltage information.

















**\*\*\*Note: Mixing of stock is only approved for FLT-SEC-H, VAL-SEC, and PLT-SEC products. Mixing of FLT-SEC-P and FLT-SEC-T1+T2 stock is not approved.\*\*\***

#### Stock Status

Can existing stock still be used?	Yes
Is mixture of stock acceptable?	Yes

#### Transaction Dates

Date modification goes into effect from Germany:	7/10/2017
Expected first shipment (from Phoenix Contact) of the modified products(s):	2/1/2018

Previous Product		New Product	
 <p>29 05 47 0 FLT-SEC-T1+T2-3S-350/25-FM U<sub>N</sub> : 240 / 415 V AC U<sub>C</sub> : 350 V AC U<sub>p</sub> : 1.5 kV I<sub>imp</sub> : 25 / 100 kA I<sub>n</sub> : 25 / 100 kA</p>	 <p>29 05 47 3 FLT-SEC-T1-350/25-FM U<sub>N</sub> : 240 V AC U<sub>C</sub> : 350 V AC U<sub>p</sub> : 1.5 kV I<sub>imp</sub> : 100 kA I<sub>n</sub> : 100 kA</p>	 <p>29 05 47 0 FLT-SEC-T1+T2-3S-350/25-FM U<sub>N</sub> : 240 / 415 V AC U<sub>C</sub> : 350 V AC U<sub>p</sub> : 2.2 kV (L-PE) I<sub>imp</sub> : 25 / 100 kA I<sub>n</sub> : 25 / 100 kA</p>	 <p>29 05 47 3 FLT-SEC-T1-N/PE-350/100-P U<sub>N</sub> : 240 V AC U<sub>C</sub> : 350 V AC U<sub>p</sub> : 1.5 kV I<sub>imp</sub> : 100 kA I<sub>n</sub> : 100 kA</p>
 <p>29 05 47 1 VAL-SEC-T1-350/25-P U<sub>N</sub> : 240 V AC U<sub>C</sub> : 350 V AC U<sub>p</sub> : 1.5 kV I<sub>imp</sub> : 25 kA I<sub>n</sub> : 25 kA</p>	 <p>29 05 47 2 VAL-SEC-T2-350-P U<sub>N</sub> : 240 V AC U<sub>C</sub> : 350 V AC U<sub>p</sub> : 1.5 kV I<sub>imp</sub> : 25 kA I<sub>n</sub> : 25 kA</p>	 <p>29 05 47 1 VAL-SEC-T1-350/25-P U<sub>N</sub> : 240 V AC U<sub>C</sub> : 350 V AC U<sub>p</sub> : 1.5 kV I<sub>imp</sub> : 25 kA I<sub>n</sub> : 25 kA</p>	 <p>29 05 47 2 VAL-SEC-T2-350-P U<sub>N</sub> : 240 V AC U<sub>C</sub> : 350 V AC U<sub>p</sub> : 1.5 kV I<sub>imp</sub> : 25 kA I<sub>n</sub> : 25 kA</p>
 <p>29 05 34 6 VAL-SEC-T1-350/25-P U<sub>N</sub> : 240 V AC U<sub>C</sub> : 350 V AC U<sub>p</sub> : 1.5 kV I<sub>imp</sub> : 20 kA I<sub>n</sub> : 20 kA</p>	 <p>29 05 47 1 VAL-SEC-T2-350-P U<sub>N</sub> : 240 V AC U<sub>C</sub> : 350 V AC U<sub>p</sub> : 1.5 kV I<sub>imp</sub> : 25 kA I<sub>n</sub> : 25 kA</p>	 <p>29 05 34 6 VAL-SEC-T1-350/25-P U<sub>N</sub> : 240 V AC U<sub>C</sub> : 350 V AC U<sub>p</sub> : 1.5 kV I<sub>imp</sub> : 20 kA I<sub>n</sub> : 20 kA</p>	 <p>29 05 47 2 VAL-SEC-T2-350-P U<sub>N</sub> : 240 V AC U<sub>C</sub> : 350 V AC U<sub>p</sub> : 1.5 kV I<sub>imp</sub> : 25 kA I<sub>n</sub> : 25 kA</p>
 <p>29 05 23 2 PLT-SEC-T3-24-P U<sub>N</sub> : 24 V AC U<sub>C</sub> : 34 V AC U<sub>p</sub> : 2 kV U<sub>oc</sub> : 250 V (L-N) / 650 V (L/N-PE) U<sub>c</sub> : 34 V DC</p>	 <p>29 05 23 2 PLT-SEC-T3-24-P U<sub>N</sub> : 24 V AC U<sub>C</sub> : 34 V AC U<sub>p</sub> : 2 kV U<sub>oc</sub> : 250 V (L-N) / 650 V (L/N-PE) U<sub>c</sub> : 34 V DC</p>	 <p>29 05 23 2 PLT-SEC-T3-24-P U<sub>N</sub> : 24 V AC U<sub>C</sub> : 34 V AC U<sub>p</sub> : 2 kV U<sub>oc</sub> : 250 V (L-N) / 650 V (L/N-PE) U<sub>c</sub> : 34 V DC</p>	 <p>29 05 23 2 PLT-SEC-T3-24-P U<sub>N</sub> : 24 V AC U<sub>C</sub> : 34 V AC U<sub>p</sub> : 2 kV U<sub>oc</sub> : 250 V (L-N) / 650 V (L/N-PE) U<sub>c</sub> : 34 V DC</p>



## Product Change Notification

*Should you have any issues with the timeline or content of this product change, please contact Phoenix Contact using the information below. Customers should acknowledge receipt of the PCN within 30 days of delivery of the PCN; provided, however, that the failure to acknowledge receipt does not affect the product change or the effective date thereof.*

**Contact Info:**

Jack Coghlan  
jcoghlan@phoenixcon.com

Thank you,

---

Matt Hemphill

Product Marketing Manager - Trabtech



Phoenix Contact Inc.  
P.O. BOX 4100  
Harrisburg, PA 17111-0100  
Phone: 717-944-1300  
Fax: 717-944-1625

## Product Change Notification

Part #	Type Description
2905414	FLT-SEC-P-T1-1C-350/25-FM
2905415	FLT-SEC-P-T1-1S-350/25-FM
2905416	FLT-SEC-P-T1-2C-350/25-FM
2905418	FLT-SEC-P-T1-2S-350/25-FM
2905419	FLT-SEC-P-T1-3C-350/25-FM
2905421	FLT-SEC-P-T1-3S-350/25-FM
2905422	FLT-SEC-P-T1-350/25-P
2905472	FLT-SEC-P-T1-N/PE-350/100-FM
2905473	FLT-SEC-P-T1-N/PE-350/100-P
2905987	FLT-SEC-P-T1-1C-440/35-FM
2905988	FLT-SEC-P-T1-3C-440/35-FM
2905989	FLT-SEC-P-T1-440/35-P
2801615	FLT-SEC-H-T1-1C-264/25-FM
2905465	FLT-SEC-T1+T2-1C-350/25-FM
2905466	FLT-SEC-T1+T2-1S-350/25-FM
2905467	FLT-SEC-T1+T2-2C-350/25-FM
2905468	FLT-SEC-T1+T2-2S-350/25-FM
2905469	FLT-SEC-T1+T2-3C-350/25-FM
2905470	FLT-SEC-T1+T2-3S-350/25-FM
2905471	FLT-SEC-T1-350/25-P
2905333	VAL-SEC-T2-1S-350-FM
2905337	VAL-SEC-T2-2C-350-FM
2905338	VAL-SEC-T2-2S-350-FM
2905339	VAL-SEC-T2-3C-350-FM
2905340	VAL-SEC-T2-3S-350-FM
2905341	VAL-SEC-T2-1S-350
2905342	VAL-SEC-T2-2C-350
2905343	VAL-SEC-T2-2S-350
2905344	VAL-SEC-T2-3C-350
2905345	VAL-SEC-T2-3S-350
2905346	VAL-SEC-T2-350-P
2905347	VAL-SEC-T2-N/PE-350-P
2905348	VAL-SEC-T2-1S-175-FM
2905350	VAL-SEC-T2-2C-175-FM
2905351	VAL-SEC-T2-2S-175-FM
2905353	VAL-SEC-T2-3C-175-FM
2905354	VAL-SEC-T2-3S-175-FM
2905355	VAL-SEC-T2-175-P
2905356	VAL-SEC-T2-N/PE-175-P
2905223	PLT-SEC-T3-24-FM
2905225	PLT-SEC-T3-60-FM
2905228	PLT-SEC-T3-120-FM
2905229	PLT-SEC-T3-230-FM
2905230	PLT-SEC-T3-3S-230-FM
2905232	PLT-SEC-T3-24-P
2905233	PLT-SEC-T3-60-P
2905234	PLT-SEC-T3-120-P



Phoenix Contact Inc.  
P.O. BOX 4100  
Harrisburg, PA 17111-0100  
Phone: 717-944-1300  
Fax: 717-944-1625

## Product Change Notification

2905235	PLT-SEC-T3-230-P
2905236	PLT-SEC-T3-3S-230-P
2905557	PLT-SEC-T3-BE
2905592	PLT-SEC-T3-3S-BE